

Utah Telecommunication
Open Infrastructure Agency



RFP # 2024GEN-001

UTOPIA Fiber answers to respondent questions
September 18, 2024

Proposal Structure

Should costs for “add-on” work like load testing be included in the pricing for maintenance or provided separately?

Please provide pricing for the semi-annual maintenance of generators separately from additional work such as fluid sampling or load testing.

Generator Site Information

Can respondents visit sites to assess access?

Yes, respondents can visit sites at any point to view access considerations. Respondents are encouraged to arrange a meeting with a UTOPIA representative to receive a tour and discuss details in person.

Do all UTOPIA generator sites have similar access levels?

Most sites offer free and open access to the generators, with a few exceptions where the equipment is secured behind gates or coded fences. The access code is uniform across all sites and will be provided to you upon contract award.

Do all generators have a transfer switch which you would like inspected?

All our generators are equipped with transfer switches, and we would appreciate an inspection as part of the service. Specific inspection requirements will be outlined upon award.